

PIPING PRESSURE TESTS

Document No.

EBL-0071



Company:	Gallon ehf.	Location:	P10120		Day:	19.01.2024	
Test cycle:	1	Test pressure:	10	Bar	Test duration:	4	Hours.

Pipes tested on this batch:

System number	Pipe size	Workload. Bar	Use	Wall thickness Mm	Tested with	
					Water	Another
P10120	DN 80	4bar	Afgreidslögn	7	Yes <input type="checkbox"/> / No <input checked="" type="checkbox"/>	DIESEL
P10120	DN 100	4bar	Afgreidslögn	7	Yes <input type="checkbox"/> / No <input checked="" type="checkbox"/>	DIESEL

Difference between highest and lowest pipe points:	3,5	Meters
Have security policies been exceeded:	Yes <input type="checkbox"/> / No <input checked="" type="checkbox"/>	
Appropriate measures have been taken to ensure safety in the area:	Yes <input checked="" type="checkbox"/> / No <input type="checkbox"/>	

Accompanying documentation

Pressure and temperature recording:	Yes <input checked="" type="checkbox"/> / No <input type="checkbox"/>	Meter calibration certificates:	Yes <input type="checkbox"/> / No <input checked="" type="checkbox"/> Tvers molar notandi
System image:	Yes <input type="checkbox"/> / No <input type="checkbox"/>	Fault report:	Yes <input type="checkbox"/> / No <input checked="" type="checkbox"/>
Test result:	Accepted Yes <input checked="" type="checkbox"/>	Rejected Yes <input type="checkbox"/>	

Comments: Afgreidslögn skipabryggja. Eskifirdi

Kerfi sett í 10 bar 13:20. Hitastig lælhas um 3,1°C
á næstu 4 klukkutímum og þrýstingur lælhas um 0,2 bar
á sama tímabili.

Signature of the developer: Ujall Anderson

PIPING PRESSURE TESTS

Document No.

EBL-0071



Signature of the inspector: Suciu Ion (Pressure gauge 1 & 2)

Cycle number: _____

Start of registration:		Time:				Day:				
Registration probability:		Time:				Day:				
Nr.	Time	Pressure (bar)	Temperature	Outdoor temperature	Nr.	Time	Pressure	Temperature	Outdoor temperature	
			12:00			19/01/2024				
			17:20			19/01/2024				
1	12:00	5/5,2	-10,3	-10,3 °C	24					
2	12:35	5/5,2	-10,6	-10,6 °C	25					
3	12:40	8/8,2	-10,6	-10,6 °C	26					
4	13:15	8/8,2	-10,8	-10,8 °C	27					
5	13:20	10/10,2	-10,8	-10,8 °C	28					
6	13:50	10/10,2	-11,1	-11,1 °C	29					
7	14:20	9,9/10,1	-11,4	-11,4 °C	30					
8	14:50	9,9/10,1	-11,8	-11,8 °C	31					
9	15:20	9,8/10	-12,3	-12,3 °C	32					
10	15:50	9,8/10	-12,8	-12,8 °C	33					
11	16:20	9,8/10	-13,4	-13,4 °C	34					
12	16:50	9,7/9,9	-13,9	-13,9 °C	35					
13	17:20	9,7/9,9	-14,5	-14,5 °C	36					
14					37					
15	metric 1	↑ ↑	metric 2		38					
16					39					
17					40					
18					41					
19					42					
20					43					
21					44					
22					45					
23					46					

Recorded by: Ion Constantin Suciu